


NOTE: THE BATTERY FUSES MUST BE APPROVED FOR 440VDC.  
 DIE BATTERIE-SICHERUNGEN MUESSEN FUER 440VDC GENEHMIGT SEIN.  
 I FUSIBILI BATTERIA DEVONO ESSERE APPROVATI PER 440VDC.  
 LES FUSIBLES POUR LA BATTERIE DOIVENT ETRE APPROUVEZ POUR 440VDC.

Sections / Querschnitte / Sezioni / Sections						Dimensions / Abmessungen Dimensioni / Dimensions			
kVA	F4 ... AgL VDC	K mm <sup>2</sup>	1/2K mm <sup>2</sup>	K mm <sup>2</sup>	1/2K mm <sup>2</sup>	PG	L mm	D mm	H mm
IEC						SEV/ASE (CH)			
10	3x25	4	4	6	6	PG9	200	150	300
20	3x50	10	10	16	16	PG21	200	150	300
30	3x80	16	16	25	25	PG21	200	150	300
40	3x80	16	16	25	25	PG21	200	150	300
60	3x125	35	25	50	25	PG21	300	200	400
80	3x160	50	25	70	35	PG21	300	200	400
100	3x200	70	35	95	70	PG29	400	200	600
120	3x250	120	70	150	95	PG29	400	200	600

MODIFICATIONS RESERVED  
 AENDERUNGEN VORBEHALTEN  
 MODIFICHE RISERVATE  
 MODIFICATIONS RESERVEES

REPLACE	SERIES	DATE	NAME
<b>LP33 Series CE</b> <b>10-20-30-40-60-80-100-120kVA</b> <b>BATTERY FUSE BOX / BATTERIESHERUNGSKASTEN</b> <b>BOX FUSIBILI BATTERIA / BOX FUSIBLES BATTERIE</b>		DES.	24.02.05 ggrassi
		CONTR.	
		MOD.	09.01.06 ggrassi
 GE Consumer & Industrial SA CH-6595 Riazzino Locarno		Pag. 1 1 Pag.	<b>391 704</b>